

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:-B- 995

Date:- 18-06-2023

NAME OF SITE

GRAM PANCHAYAT- Bajhera

BLOCK- Samrer

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BAJHERA, BLOCK- SAMRER, DISTT.- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 18.June.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Fine sand	
3.	8 - 12	4	Clay kankar	
4.	12 - 18	6	Fine to Medium sand	Good
5.	18 - 25	7	Clay kankar	
6.	25 - 32	7	Fine to Medium sand	Good
7.	32 - 40	8	Clay kankar	
8.	40 - 43	3	Fine sand	Good
9.	43 - 47	4	Clay kankar	
10.	47 - 57*	10	Medium sand	Good
11.	57 - 62	5	Clay kankar	
12.	62 - 80*	18	Medium sand & kankar	Good
13.	80 - 91	11	Clay kankar	
14.	91 - 101*	10	Medium sand	Good
15.	101 - 111	10	Clay.kankar	
16.	111 - 126*	15	Medium sand	Good
17.	126 - 130	4	Clay kankar	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
N16 (SN)
N64(LN)
LAT

Logging Details:

Logging via Data Book
Damer Datt Badaun
UP LOGGING Co.
10 Jul 2023
22:43
Uttaranchal gupta (bhal)

Logger S No:

IGIS/S/01/10-11

SP (m V)

Logger Model:

DMPL-2

Logger Owned by:

GROUND WATER
SURVEY
CONSULTANCY
- AGRA INDIA

