



GSTIN. 03BNPPS2540N1ZK

# M/S E.R. TECHNOLOGIES

(Govt. Contractor of PH & Civil Works & Electrical Works)

(Specialist in: Deep Tube well, Sick Tube well, Geological and Hydro-Geological Survey, Electric Logging of Borehole, Videography of Borehole, Water Sample & Soil Testing etc.)

Ref. ....

Dated... 04/02/2024 .....

## REPORT OF ELECTRIC LOGGING OF BOREWELL DRILLED AT SITE VILLAGE BHAISAMAI & FAKEERABAAD, BLOCK SALARPUR, DISRICT BUDAUN, UTTAR PRADESH UNDER JAL JEEVAN MISSION

### Introduction:

The borehole at the site was drilled to a depth of 130.00 meters, and the electric logging was conducted up to 130.00-meter depth using a continuous logger on Feb 04, 2024. The purpose of this logging was to assess the various subsurface strata and properties encountered during drilling, with a focus on resistivity measurements (LON -64" and SHN-16) and self-potential (SP) data. This report provides an analysis of the interpreted data and offers recommendations for further actions under the Jal Jeevan Mission.

Name of agency	PNC Infra, UP Boring & Pipe Store
Location	Bhasisamai & Fakeerabaad
Block	Salarpur
District	Budaun, U.P
Depth drilled (mbgl)	130
Depth logged (mbgl)	130
Water level (m)	12
LON -64" Resistivity (N-64)	Ohm.m (Blue)
SHN-16 Resistivity (N-16)	Ohm.m (Red)
Self-Potential (SP)	Mv (Green)

Sr. No	Depth Range (m)		Zone Thickness(m)	LON -64" N Resistivity (ohm.m)	Probable Strata	Expected water Quality
	From	To				
1	0.00	7.00	7.00	<20	Top Soil	-
2	7.00	36.00	29.00	67	Medium Coarse Sand	-
3	36.00	41.00	5.00	36	Clay	-
4	41.00	84.00	43.00	76	Coarse sand, Gravel	Good
5	84.00	86.00	2.00	25	Clay	-
6	86.00	104.00	18.00	79	Coarse sand, Gravel	Good
7	104.00	110.00	6.00	24	Clay	-
8	110.00	118.00	8.00	80	Medium Coarse Sand	Good
9	118.00	130.00	12.00	25	Clay	-

Regd. Office: 7-A Shanti Nagar , Rajpura Sirhind Bye Pass Road, Near St. Xavier's School

Mobile: 98140-33654, 98721-62830 Office Phone: (0175) 2911516

E-mail:- ertechnologies1516@gmail.com



GSTIN. 03BNPPS2540N1ZK

# M/S E.R. TECHNOLOGIES

(Govt. Contractor of PH & Civil Works & Electrical Works)

(Specialist in: Deep Tube well, Sick Tube well, Geological and Hydro-Geological Survey, Electric Logging of Borehole, Videography of Borehole, Water Sample & Soil Testing etc.)

Ref. ....

Dated.....04/02/2023.....

SITE VILLAGE BHAISAMAI & FAKEERABAAD, BLOCK SALARPUR, DISRICT BUDAUN,

## Recommendations:

Based on the interpreted strata data from the electric logging, the following recommendations are provided:

**1. Screen Installation:**

It is recommended to install screens against the **bold-marked strata** indicated in the interpretation above. These screens will help facilitate water inflow from the identified permeable zones.

**2. Expected Water Quality:**

The expected water quality in the zones marked as "Good" is anticipated to be favorable.

**3. Tubewell Development:**

To optimize water yield, it is advised to develop the tubewell using a high-capacity air compressor.

Interpretation Done By...

**PARKASH KUMAR**  
Hydrogeologist

Regd. Office: 7-A Shanti Nagar , Rajpura Sirhind Bye Pass Road, Near St. Xavier's School

**Mobile: 98140-33654, 98721-62830 Office Phone: (0175) 2911516**  
E-mail:- ertechnologies1516@gmail.com