


PROPOSED ASSEMBLY CHART OF W/S Scheme - GAURI BANİYANI

Block - Fatehpur, Dist. - Barabanki

Discharge 200 LPM
 Motor HP - 7.5 HP
 Assembly Size - 200*150 Ø
 Bore - 500*450 mm Ø
 Logging Report : 20.04.2023

STRATA CHART		
Depth in Mtr	Thickness in MTR	Type of Strata
23-27	4	GOOD
41-48	7	GOOD
52-64	12	GOOD
70-75	5	GOOD
95-101	6	GOOD
108-116	8	GOOD
120-124	4	GOOD
129-132	3	GOOD



JUNIOR ENGINEER
[Signature]

ASSISTANT ENGINEER
[Signature]

EXECUTIVE ENGINEER
[Signature]

M/s Mahalaxmi Tube Well

Rajnendra Nagar Pukhrayan Kanpur 9935299290

Geophysical Well Logging Report

Ref No -04/209 Date -20/04/2023

Site Location : - Gauri Baniyani Fatehpur Barabanki

District : - Barabanki

Logged Depth : - 165 M BGL

Date of Logging : - 20/04/2023

Types of Log : - S.P & N16, N-64 LAT

Logger used : - IGIS

The following permeable granular zones have been deciphered with the

help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L	Thickness Mtr.	Inferred Lithology	Quality of G.W.
1	23	27	04	Fine to Medium sand	Good
2	41	48	07		
3	52	64	12		
4	70	75	05		
5	95	101	06		
6	108	116	08		
7	120	132	12		
8					

Note: All zones are intermixed with fine bands of kanakar

- Sr No 7-120-124

(4m)

and 129-132(3m) M/s Mahalaxmi Tube Well

- Logging performed as per

SRM guidelines

- Groundwater quality

interpreted by firm

as per their loggers

collaboration

G.S.R

21/04/23