

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No - 377

Date 22/01/2022

NAME OF SITE
MATNAWALI
BLOCK- HAPUR
DISTRICT-HAPUR

SUBMITTED BY
L C INFRA PROJECTS PVT LTD
AHMADABAD

M/S MAHALAXMI TUBE WELL
CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-
LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR
RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111
9935299290, 8090118811, mahalaxmitubewell@gmail.com
ISO ; 9001:2015

Geophysical Well Logging Report

Ref No - 377

Date 22/01/2022

Site Location :- Village – Matnawali Hapur

District :- Hapur

Logged Depth :- 125 M BGL

Water Level :- 10+-2

Date of Logging :- 22/01/2022

Types of Log :- S.P & Resistivity

Logger used :- IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger

Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Litho logy	Quality of G.W.
0	12	12	Surface Clay with Fine Sand and Kankar	
12	18	06	Fine to medium Sand	Good
18	25	07	Sandy Clay	
25	35	10	Fine to medium Sand	Good
35	49	14	Clay	
49	58	09	Fine To Medium sand	Good
58	85	27	Sandy Clay	
85	120	35	Fine To medium Sand	Good
120	125	05	Sandy Clay	

Dr.R.Srinivasa Chary

(Geologist)

Rho a
N16(SN)
N64(LN)
LAT

Location :
Mazraei Harur Harur
Log No :
DNM100GMS
Date :
Sat Jan 22 2022
Time :
11:54 AM
Observer :
Well Depth :

SP

