



Date  
07/12/22

Mehdupur GP WSS T/W, Block, Santha, Mehdawal <sup>SKN</sup> <sub>classmate</sub>

M/S Megha Engineering & Infrastructure Ltd.

Date \_\_\_\_\_  
Page \_\_\_\_\_

Bore size 165m/150m (550mm x 500mm)

Assembly size 200x150mm

Required Discharge -> 550 LPM

Logging Report date -> 30-11-22

S. No	Depth Range	Thickness
1	20 - 33 m	13 m
2	57 - 70 m	13 m
3	80 - 87 m	7 m
4	90 - 95 m	5 m
5	121 - 131 m	10 m
6	136 - 140 m	4 m
7	139 - 163	4 m

Note - All zones are intermixed with fine bands of kankar. S.No 4 is fine sand, S.No- 5 & 6 are highly kankar intermixed.

