

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No - 385

Date 25/01/2022

NAME OF SITE

CHATAULI
BLOCK- HAPUR
DISTRICT-HAPUR

SUBMITTED BY

L C INFRA PROJECTS PVT LTD
AHMADABAD

M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-
LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR
RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111
9935299290, 8090118811, mahalaxmitubewell@gmail.com

ISO ; 9001:2015

Geophysical Well Logging Report

Ref No - 385

Date 25/01/2022

Site Location :- Village – Chaitauli Hapur

District :- Hapur

Logged Depth :- 125 M BGL

Water Level :- 07+-2

Date of Logging :- 25/01/2022

Types of Log :- S.P & Resistivity

Logger used :- IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger

Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Litho logy	Quality of G.W.
0	6	6	Surface Clay with Fine Sand and Kankar	
6	20	14	Fine to medium Sand	
20	27	07	Sandy Clay	
27	36	09	Fine to medium Sand	Good
36	44	08	Clay	
44	77	33	Fine To Medium sand	Good
77	91	14	Clay	
91	103	12	Fine To medium Sand	Good
103	120	17	Sandy Clay	
120	123	03	Fine To medium Sand	Good

Dr.R.Srinivasa Chary

(Geologist)

Rho a
NL6 (SN)
N64(LN)
LAT

Chirail Hapur Hapur dn
DOWN LOGGING
Tue Jan 25 2022
2:43 PM

SP (m V)

