# GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No -412

Date 01/02/2022

### NAME OF SITE VILAGE- ABDULLAPUR BASANTPUR Urf FARID BLOCK – HAPUR

## NAME OF AGENCY L.C. INFRA PROJECTS PVT LTD AHMADABAD

## M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111 9935299290, 8090118811, mahalaxmitubewell@gmail.com ISO; 9001:2015

### **Geophysical Well Logging Report**

Ref No- 412

Date 01/02/2022

Site Location : - Village – Abdullapur Basantpur District :- Hapur

District :- Hapur Logged Depth :- 143 M BGL

Date of Logging :- 01/02/2022

Types of Log :- S.P & Resistivity

Logger used :- IGIS

The following permeable granular zones have been deciphered with the help of

Electrical Logger.

Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Litho logy	Quality of G.W.
0	4	4	Surface Clay With Kankar	
4	16	12	Fine to Medium Sand	Good
16	25	09	Sandy Clay	
25	32	07	Fine to Medium Sand	Good
32	42	10	Fine Sandy Wth Clay	
42	68	26	Fine to Medium Sand	Good
68	87	19	Clay	
87	104	17	Fine to Medium Sand	Good
104	115	11	Clay	
115	125	10	Fine to Medium Sand	Good
125	143	18	Sandy Clay	

com

Dr.R.Srinivasa Chary ( Geologist )

