

# **GEO-PHYSICAL WELL ELECTROLOGGING REPORT**

Re No – 544

Date 05/03/2022

## NAME OF SITE

GHITURA  
KHEKHRA  
BAGHPAT

## NAME OF AGENCY

L.C INFRA PROJECTS PVT. LTD  
AHAMDABAD

## **M/S MAHALAXMI TUBE WELL**

**CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-  
LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR**

**RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111**

**9935299290, 8090118811, mahalaxmitubewell@gmail.com**

**ISO ; 9001:2015**

# M/S MAHALAXMI TUBE WELL

## Geophysical Well Logging Report

Ref No – 544

Date 05/03/2022

Site Location :- Village :- Ghitura Block Khekhra

District :- Baghpat

Logged Depth :- 135 M BGL

Date of Logging :- 05/03/2022

Water Level :- 25+-2

Types of Log :- S.P & Resistivity

Logger used :- IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger .

Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Lithology	Quality of G.W.
0	26	26	Surface Clay With Fine sand Kankar	
26	38	12	Fine sand with kankar	Good
38	43	05	Sandy Clay Kankar	
43	48	05	Fine to medium sand	Good
48	57	09	Clay	
57	70	14	Fine to medium sand	Good
71	135	64	Sandy Clay Kankar	

M/s Mahalaxmi Tube Well

Prop

Rho a  
N16 (SN)  
N64(LN)  
LAT

Ghitura Khekha  
Bagpat  
LOGGING 01  
Sat, Mar 05, 2022  
12:13 PM

SP (m V)

