

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:-A-64

Date:- 27-05-2024

NAME OF SITE

Gram Panchayat- Pasai Anthuiya

BLOCK- Kadar Chauk DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- PASAI ANTHUIYA, BLOCK-KADAR CHAUK, DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 27.May.2024.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-


S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 20	15	Dry sand	
3.	20 - 30	10	Clay kankar	
4.	30 - 47	17	Fine sand	
5.	47 - 65	18	Clay kankar	
6.	65 - 75*	10	Medium sand	Medium
7.	75 - 95	20	Clay kankar	
8.	95 - 115*	20	Fine to Medium sand & Kan	Medium
9.	115 - 130	15	Clay kankar	



Ground Water Survey Consultancy
Agra

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tube well.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Rho a
 N 16(S/N)
 N 64 (LN)
 LAT

Location:
 Logging GP 9988
 Aranya Book
 Chaudhary Dr. Budhan
 log No:
 UP (CGS)GP
 Date:
 27 May 2024
 Time:
 20:33
 Operator:
 Ushant Gupta (AG)
 Well Depth:

Logger S No.:
 IGIS/S/01/10-11

SP
 Logger Model:
 DMPL-2
 Logger Owned by:
 Ground Water
 Survey Consultancy
 Agra UP India

