



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029

Mobile : 9818 888 824, 9818 007 038

E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

KUSU

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :


Date : 15.03.2022

Village : HASANPUR

Block : Buland Sahar

District : Buland Sahar

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface soil	
3-7	clay	
7-14	Fine Sand	
14-35 [⊗]	medium sand	good
35-44	clay kankar	
44-56 [⊗]	medium sand	good
56-60	sandy clay	
60-69 [⊗]	medium sand	good
69-79	clay	
79-113 [⊗]	medium to fine sand	good
113-138	clay kankar.	



For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE
 ▼ WATER LEVEL :14..... METRES

(Signature)
 M. RAJESH
 15/3/2022