## GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No - 457

Date 12/02/2022

NAME OF SITE NAWADA PILANA BAGHPAT

NAME OF AGENCY
L.C. INFRA PROJECTS PVT. LTD.

## M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111 9935299290, 8090118811, mahalaxmitubewell@gmail.com

ISO; 9001:2015

## **Geophysical Well Logging Report**

Ref No – 457 Date 12/02/2022

Site Location : - Village :- Nawada Pilana

District :- Baghpat
Logged Depth :- 135 M BGL
Date of Logging :- 12/02/2022

Water Level :- 8+-2

Types of Log :- S.P & Resistivity

Logger used :- IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger .

Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Litho logy	Quality of G.W.
0	40	40	Surface Clay Sand With Fine sand Kankar	
40	52	12	Fine To Medium sand	Good
52	66	14	Sandy Clay	
66	73	07	Fine To Medium sand	Good
73	85	12	Clay	
85	97	12	Fine To Medium sand	Good
97	135	38	Clay	

Dr.R.Srinivasa Chary

(Geologist)

