



Contract: m/s. welspun Enterprises



**GLOBAL GROUND WATER CONSULTANTS**

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029  
 Mobile : 9818 888 824, 9818 007 038  
 E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

**GEOPHYSICAL ELECTRICAL LOGGING REPORT AT**

Tubewell No. : .....

Date : 11.03.2022

Village : Kurema

Block : Jahngherabad

District : Buland shahar, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface soil	
3-11	Fine sand	
11-19 <sup>⊗</sup>	medium sand	Good
19-28	Sandy clay	
28-36 <sup>⊗</sup>	medium sand	Good
36-41	clay	
41-80 <sup>⊗</sup>	medium sand	Good
80-85	clay	
85-94 <sup>⊗</sup>	Fine sand	Good
94-110	clay	
110-117 <sup>⊗</sup>	Fine sand	Good
117-141	clay	
141-153 <sup>⊗</sup>	Fine sand	Good
153-154	clay	

For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE  
 ▼ WATER LEVEL : 9 METRES

*Srikanth*  
 M. RAVI KANTH  
 11/3/2022

Consulting Geologists, Geophysists & Ground Water Specialists



Karena (Bansari) 41-80-M  
 (Jahangirabada, Wazirpur) 85-94-F  
 850 LPM, 300x200 110-117-F  
 DAY 147-218 | WK 22 141-153-F

**27** THURSDAY MAY 2021

300mm φ plain - 6.01, 6.03, 6.02, 6.02, 6.01, 6.60, 6.10 = 42.79

200mm φ plain - 6.01, 6.01, 6.01, 6.02, 6.01, 6.01, 6.01, 6.02  
 6.01 = 60.12 (3.02+3.00) (4.02+2.00)

200mm slotted - 6.00, 6.00, 6.00, 3.00, 3.00 = 24.00m

11	6.01	40.44	Logg - 11.03.22 → (150m/154m) Lowering -
12	6.03		
	6.02		
	6.02		
1	42.79	6.01	
		6.60	
2		6.10	
		42.35	
	6.01	42.50	
3	6.01	48.51	
	6.01	54.51	
4	6.01	60.52	
	6.01	66.52	
5	6.01	72.53	
	6.01	78.53	
6	10.03	4.02	
	3.00	88.56	
	3.00	91.56	
7	6.01		
	6.01		
21-05	6.01		
NOTES	3.02	112.61	
	3.00	115.61	
	6.01	121.62	

MAY	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S
2021	30	31	.	.	.	.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29