

Aqua Xplore

(Groundwater Assessment & Allied Services)
243/5, New Colony Jiyamsu, Hazratganj, Lucknow - 226001
Mob. 9918202546 / 9880323322, E mail- aquaxplorelko@gmail.com

Ref. 1224 - G / AX - 2021

Date 24.12.2021

Geophysical Borehole Logging Report

Name of the site : Gobraha, Block - Kon

District : Mirzapur

Date : 24.12.2021

Depth logged : 58.0 mbgl

Depth drilled : 62.0 mbgl -reported

Logger used : Aqua Xplore

Presence : Rep. of M/S G.A. Infra Pvt. Ltd., Muzaffarnagar.

Based on the interpretation of geophysical logs, following information may be deciphered, particularly with respect to salinity of the formation water.

Sl.No.	Depth range(mbgl)	Thickness(m)	Remarks
1	23.0---28.0	5.0	Good all
2	30.0---33.0	3.0	
3	35.0---48.0	13.0	
4	50.0---55.0	5.0	

Note. All zones are Intermixed with kankar.



for Aqua Xplore

CC;
M/S G.A. Infra Pvt. Ltd.
Muzaffarnagar


OFFICE OF THE EXECUTIVE ENGINEER UNICEF PROJECT UNITE (E/M) U.P. JAL NIGAM (GRAMIN) SONBHADRA
 ACTUAL COMPLETION PLAN OF GOBRAHA (MAHAURI GROUP OF VILLAGE WATER SUPPLY SCHEME UNDER J.J.

BLOCK - KON, DISTRICT - MIRZAPUR

311122

- 1. T.W. constructed by :M/S G.A. Infra
- 2. T.W. constructed :900lpm
- 3. Pumping Plant :550 lpm
- 3. Depth logged :58.00 mbgl
- 4. Depth drilled :62.00 mbgl
- 5. Size Of Bore :600 mm
- 6. Size Of T.W. :250 mm
- 7. Assembly Lowered & Pea Gravel Feed on Dt. :.....

Logging Report-
 Logging Date :24.12.2021
 Logging By : Aqua Explore



S.N.	Depth Range in Mtr (B.G.L.)	Thickness(Mtr)	Remark
1	23.0 to 28.0 mbgl	5.00M	Good
2	30.0 to 33.0 mbgl	3.00M	Good
3	35.0 to 48.0 mbgl	13.00M	Good
4	50.0 to 55.0 mbgl	5.00M	Good

[Signature]
 CONTRACTOR

[Signature]
 PMC

[Signature]
 JUNIOR ENGINEER

[Signature]
 ASSISTANT ENGINEER

[Signature]
 E.E.