

## GEO – TECHNICAL CONSULTANT

(Division of MACHTECH)

Plot no. 61 Vikaskung, Near Tower, Dibiyapur – 206244, District – Auraiya, Uttar Pradesh (India)

E-mail: [machteertools55@gmail.com](mailto:machteertools55@gmail.com) , Mobile Number :- 9265018387

Ref : MTL/WL/23-24/4

Date : 03.04.2023

### REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

A deep borehole was drilled by working agency M/s. M/s. VTL- GAJA (JV) as a part of their scope of work of development of Tubewell under Jal Jeevan Mission Project of SWSM, MTL conducted a Geophysical Continuous logging in the above borehole.

Village Name	HARIHARPUR
Block	SHAHGARH
District	AMETHI, U.P.
Logged Depth	157.5 Mtr BGL
Type of Log	Continuous well logger (SP, N16 (SN), N64 (LN) & LAT)
Machine Used	JGIS
Logging Date	02.04.2023

The following aquifer zones have been deciphered with the help of logging machine.

Sr. No.	Depth Range (mtr BGL)	Thickness (mtr)	Expected Quality
<del>1</del>	31 – 38	7	Good
<del>2</del>	55 – 59	4	Good (Fine Sand)
<del>3</del>	64 – 67	4	Good (Fine Sand)
<del>4</del>	90 – 97	7	Good

~~Rw – 15.2 Ohm mtr and Rm – 14.9 Ohm mtr~~

Note: Below 104 MBGL the quality of the formation water is marginal to saline till log depth.

- Logging performed as per SWSM guidelines.  
- Groundwater quality interpreted by firm as per their logger calibration

For Geo-Technical Consultant,



Authorised Signatory

GSh  
03/04/23