



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Date: 11/1/23

Ref No.

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency: M/S. Vindhya Tech. Sols. Pvt. Tejvihar Supt.
 Village: Maksu dabad Block: Antal gram
 District: AGRA Logging Depth: 140 mtr
 Drilling Depth: 150 mtr Water Level: 2 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Blue-grey Silty	
2	5 - 10	Clay	
3	10 - 15	Fine to Med Sand	Medium
4	15 - 20	clay loam	
5	20 - 25	Medium Sand	Medium
6	25 - 30	clay loam	
7	30 - 39"	Medium Sand	Medium
8	39 - 54	clay loam	
9	54 - 79"	Medium Sand clay	Medium
10	79 - 91	clay loam	
11	91 - 95	Fine Sand	Medium
12	95 - 100	clay loam	
13	100 - 110"	Medium Sand	Medium
14	110 - 115	clay loam	
15	115 - 135"	Medium Sand	Medium
16	135 - 140	Sandy clay	
17			
18			
19			
20			
21			
22			
23			

Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.