

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:-A- 630

Date:- 25-05-2023

### NAME OF SITE

GRAM PANCHAYAT- Sahadpur Gulal      BLOCK- Noorpur      DISTT- Bijnor

### NAME OF AGENCY

LC Infra Projects Pvt. Ltd.- TCEL(JV)  
Bijnor



## GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.  
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- SAHADPUR GULAL, BLOCK- NOORPUR,  
DISTT- BIJNOR  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 160 mtrs. depth. and Logged depth 156 mtrs. at above site. Was drilled by M/s LC Infra Projects Pvt. Ltd.- TCEL(JV), Bijnor.

On the request of M/s LC Infra Projects Pvt. Ltd.- TCEL(JV), Bijnor. A Geophysical well Logging in the above bore hole using IGIS Well Logger on 25.May.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Clay kankar	
3.	10 - 35	25	Fine sand	
4.	35 - 70*	35	Medium sand	Med to Good
5.	70 - 80	10	Clay kankar	
6.	80 - 109*	29	Medium sand	Med to Good
7.	109 - 115	6	Clay kankar	
8.	115 - 150*	35	Medium sand	Med to Good
9.	150 - 156	6	Clay kankar	



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**



Rho a  
 N16(SN)  
 N64(LN)  
 LAT

LOGGING: V. JARASOL  
 G. S. & S. S. JARASOL  
 D. J. S. JARASOL  
 Log No.:  
 V. JARASOL  
 Date: 25/09/2023  
 Time: 11:11  
 Client: URBAN GROUP (S)  
 Web: www.urbangroup.com

Logger S. No.:  
 IGIS/S/01/21-22

SP  
 Logger Model:  
 DMPL-2  
 Logger Chases by:  
 GROUND WATER SURVEY CONSULTANCY Agra UP, India

