GLOBAL GROUND WATER CONSULTANTS
84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9818 886 824, 9818 007 038
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. : .....
Date : 04/05/2022
Village : PRAKASHPUR
Block : Scheme PRAKASHPUR - NAGLA CHTTU
District : DANPUR
BULAND SHAHAR, U.P.

Depth in Metres	Expected Litholog	Expected Water Quality
0-3	Surface soil	
3-6	Fine Sand	
6-12 ⊛	Fine Sand	Good
12-35 ⊛	Medium Sand	Good
35-38	Sandy clay	
38-44 ⊛	Fine Sand	Good
44-46	Sandy clay	
46-69 ⊛	Medium Sand	Good
69-75	Kankar	
75-85 ⊛	Fine Sand	Good
85-114	clay	
114-124	Kankar clay	
124-147	clay	

For Global Groundwater Consultants

(SRIKANTH)

⊛ EXPECTED WATER ZONE
▼ WATER LEVEL : ..... 6. METRES

Consulting Geologists, Geophysists & Ground Water Specialists