

contract: mls. well 20m



GLOBAL GROUND WATER CONSULTANTS

64-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
 Mobile : 9818 888 924, 9818 007 038
 E-mail : srikanthchukka.c23@gmail.com, ravikanth44@yahoo.com

K. Srinivas
 Geophysicist

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No.

Date : 24.03.2022

Village : Jeeroat

Block : Lakhawati

District : Bulandshahr

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface Soil	
3-6	sandy clay	
6-15	fine sand	
15-49	medium sand	good
49-56	fine sand	good
56-61	clay	
61-68	fine sand	good
68-84	clay kankar	
84-102	medium sand	good
102-114	fine sand	good
114-138	clay kankar	
138-142	very fine sand	good
142-150	sandy clay	

⊗ EXPECTED WATER ZONE
 ▼ WATER LEVEL : 15 METRES

For Global Groundwater Consultants

M. Ravi Kant
 M. RAVI KANT
 24/3/2022

Jeelot W/S
(Lakhoti, Walspur) (300X150)

700 LPM

07

DAY 158-207 | WK 24

MONDAY

15-49 - M-Sand
49-56 - F Sand → 61-68 - F
84-102 - M
109-114 - F

SWL - 15m

600X500 - (75, 25+50) - 150
300X150 - (77-35, 30, 30) - 135
ms. 13, Grand - 38.21

JUNE

300mm Housing - 6.04, 6.02, 6.03, 6.02, 6.02, 6.02, 6.02, 6.02, 3.00 = 51.19

150mm Plain - 6.00, 5.99, 5.97, 5.98, 6.00, 5.98, 5.99 = 41.91

150mm Spotted - 6.00, 6.00, 6.00, 6.00, 3.00 = 27.00

	6.04	10.44
	6.02	
	6.03	
	6.02	
1	6.02	
	6.02	
2	6.02	
	6.02	
	3.00	50.75
3	6.00	50.90
	11.99	5.99
	3.00	62.89
4	5.97	65.89
	5.98	
5	19.83	5.98
	2.00	85.82
6	12.00	6.00
	6.00	97.82
7	3.00	100.82
	6.00	
NOTES	12.00	6.00
	3.00	112.82
	6.99	3.99
		119.81

Logg. 24.03.22 (150m)
Lowering - 25.03.22

JUNE
2021

S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S
.	.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	.	.	.