GLOBAL GROUND WATER CONSULTANTS
84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9818 888 824, 9818 007 038
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

Indirapuram
Shivam

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. : .....

Date : 09/05/2022

Village : Jalphi Karena

Block : pahasu

District : Buland shahar, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3	Surface soil	
3-11	Medium sand	
11-32 ⊗	Medium sand	Good
32-40 ⊗	Fine sand	Good
40-63	Sandy clay	
63-86 ⊗	Medium sand	Good
86-92	clay	
92-98 ⊗	Fine sand	Good
98-131	clay	
131-135 ⊗	Very fine sand	
135-139	Sandy clay	
139-150	clay	

For Global Groundwater Consultants

(SRIKANTH)

⊗ EXPECTED WATER ZONE

WATER LEVEL : .....11 METRES