

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....

Date 4.6.23

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES


Name Of Agency L.C. Infra. I.R.S. Enterprises

Village Musapur Block Hajebabad

District Bagnor Logging Depth 140 mt

Drilling Depth 161 mt Water Level 10 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 15	clay loam	
3	15 - 30	fine to med sand	Medium
4	30 - 35	clay loam	
5	35 - 41	fine to med sand	Medium
6	41 - 51	clay loam	
7	51 - 62	medium sand	Medium
8	62 - 65	clay loam	
9	65 - 80	medium sand	Medium
10	80 - 85	clay loam	
11	85 - 93	medium sand	Medium
12	93 - 111	clay loam	
13	111 - 135	medium sand	Medium
14	135 - 140	clay loam	
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Singh*  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Well Rectification of Tubewells, Ground Water Investigations