



GLOBAL GROUND WATER CONSULTANTS m/s. Pump

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029

Mobile : 9818 888 824, 9818 007 038

E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : 14.04.2022

Village : Ahmadpur Tanda

Block : Agota

District : Bulandshahr, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surbe Soil	
3-10	Sandy clay	
10-21	Very fine sand	Good
21-33	Fine sand	Good
33-42	clay kankar	
42-56	medium to fine sand	Good
56-60	Sandy clay	
60-75	medium sand	Good
75-83	clay kankar	
83-113	medium sand	Good
113-116	clay kankar	
116-121	Fine sand	Good
121-133	clay kankar	
133-137	Sandy clay	
137-150	clay kankar.	

For Global Groundwater Consultants

EXPECTED WATER ZONE

WATER LEVEL :14..... METRES

M. RAVIKANTH

 14/4/2022

30)-130
)-120
 -120
 70-16
 E
 29

Ahmadpur Tanda 42-56 - M.
 (Agota, Walspur) 60-75 - M
 300x200 83-113 - M
 (775 LPM) 116-121 - F
 JUNE SWL-14m

600x500 - (60, 40+50) - 150
 300x200 - (54, 51-30) - 135
 Learning - (54, 46, 35) - 13, MS-135
 WK 27 | DAY 181-184
 Grand - 75.51
 WEDNESDAY 30

300mm Hoisting - 6.02, 6.00, 6.00, 6.00, 6.03, 6.02, 6.01, 6.01 = 48.09

200mm Plain - 6.00, 6.01, 6.00, 6.00, 6.01, 6.01, 3.00, 2.00 = 41.03

200mm slotted - 6.00, 6.00, 6.00, 6.00, 6.00 = 30.00

11	6.02	10.44
	6.00	
	6.00	
12	6.00	
	6.03	
1	6.02	
	6.01	
2	6.01	47.65
		47.80
3	6.00	
	6.00	
	2.00	61.80
4	6.00	
	6.00	
		73.80
5	6.00	
	6.01	85.81
6	6.00	
	6.00	
		97.81
7	6.01	103.82
	6.00	109.82
NOTES	6.01	115.83

Logg - 14.04.22 (150.0m)
 Learning.

S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	S	M	T	W	T	F	S	JULY
.	.	.	.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	2021