

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 3.3.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- LC Infra Pvt Ltd SRS Enterprises

Village - Shamshabad Block- Melthapur

District- Bagpat Logging Depth- 145 m

Drilling Depth- 160 m Water Level- 12 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	Dry Sand	
3	10-15	clay	
4	15-20	fine sand	
5	20-35	clay beds	
6	35-45	fine sand	
7	45-70*	medium sand	medium
8	70-75	clay beds	
9	75-85*	medium sand	medium
10	85-90	clay beds	
11	90-107*	medium sand	medium
12	107-115	clay beds	
13	115-120	medium sand	medium
14	120-145	clay beds	
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sandeep
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.