



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029

Mobile : 9818 888 824, 9818 007 038

E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

KUSOU

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : 2.04.2022

Village : Nangla Alampur

Block : Uncha Gaon

District : Buland Sahar, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface soil	
3-13	Fine sand	
13-21 [⊗]	Fine sand	good
21-25	clay	
25-36 [⊗]	medium sand	good
36-42	Sandy clay	
42-66 [⊗]	medium sand	good
66-75 [⊗]	medium to fine sand	good
75-92	clay kanker	
92-111 [⊗]	medium sand	good
111-114	sandy clay	
114-119 [⊗]	medium sand	good
119-122	sandy clay	
122-144 [⊗]	Fine sand	good
144-149	Sandy clay	

For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE

▽ WATER LEVEL : ...1.3..... METRES

M. Ravikanth
M. RAVIKANTH
21/4/2022

23

DAY 174-191 | WK 26
WEDNESDAY

JUNE

2021

300x150
400LPM

42-66-M
66-75-M-F
92-111-M
114-119-M
122-144-F
SWL-13

300mm Hausing - 6.03, 6.02, 6.02, 6.02, 6.02, 6.02, 6.01, 6.01 = 48.15

150mm slotted - 6.00, 6.00, 5.99, 6.00, 6.00, 6.00, 5.98, 5.97

6.00, 5.99 = 59.93 (4.19 + 1.78)

150mm slotted - 6.00, 6.00, 3.00, 3.00 = 18.00

11		6.03	0.45
12		6.02	
		6.02	
		6.02	
1	48.15	6.02	
		6.02	
2		6.01	
		6.01	47.70
3		6.00	47.85
		6.00	53.85
4	9.00	6.00	
		3.00	
		6.00	62.85
5		5.99	
		6.00	
6	35.97	6.00	
		6.00	
7		5.98	98.82
		6.00	104.82
NOTES	10.18	5.99	
		4.19	115.00
		3.00	118.00
		6.00	124.00

Logg - 2.04.22 (149m)
Lawerly - 2.04.22