


Proposed Tw Assembly chart of Kakwa w/s scheme block Amethi Distt - Amethi



- 1- Discharge 565 LPM
- 2- Assembly size 200x150mm
- 3- Bore $\phi = 500 \times 450$ mm
- 4- Logging Report dt-14-4-2

- 1- 13-20 = 7 good
- 2- 53-63 = 10 good

Below 72m bgl the quality of the formation water is marginal to saline till log depth.