



Contractor: M/S. Welspon



GLOBAL GROUND WATER CONSULTANTS

M/S. A.N. EGY

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9818 888 824, 9818 007 038
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

Aman

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : ..24.5.2022

Village : SHERPUR

Block : DHANPUR

District : BULANSAHAR, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface soil	
3-14	medium sand	
14-45	medium sand	good
45-49	Very fine sand	good
49-56	medium sand	good
56-61	Very fine sand	good
61-70	Fine sand	good
70-76	clay	
76-88	Fine sand	good
88-96	clay	
96-101	medium sand	good
101-117	clay	
117-121	sandy clay	
121-138	clay kankar	
138-143	sandy clay	
143-150	clay kankar.	

For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE

▽ WATER LEVEL :14..... METRES

(Signature)
M. RAJ KANTH
24/5/2022

Consulting Geologists, Geophysists & Ground Water Specialists