

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

of No.....

Date 14.2.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency LC Infra Ltd LC Infra (Shubham)
 Village Sura Nagla Block Buatharapur
 District Prayagraj Logging Depth 155 mtr
 Drilling Depth 160 mtr Water Level 3 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay	
3	10 - 49	medium Sand	Medium
4	49 - 55	clay with	
5	55 - 95	medium Sand	medium
6	95 - 100	clay with	
7	100 - 110	medium Sand	Medium
8	110 - 120	clay with	
9	120 - 130	fine + med Sand	Medium
10	130 - 155	clay with	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.