

Ref No: LSA19

Date: 14/05/2022

**GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD
 DETAIL OF WATER BEARING ZONES**

LAT: LONG:

Name of agency: Woodhill Infrastructure Ltd.
 Village: Ramigala Bagalpur Block: Nulsar
 District: Saharanpur Logging Depth: 154.5
 Drilling Depth: 160 m Water Level: 11 m
 Co. Rep.: Mr Saini

S.No	Depth in Mtr.	Start Depth	End Depth	Width	Expected Geology	Expected Depth
1		0	40		Top Soil	
2		40	47		Sand Med	
3		47	51		Clay	
4		51	54		Sand Med	Water
5		64	71		Clay	
6		71	91		Sand Med	Water
7		91	107		Clay	
8		107	111		Sand Med	Water
9		111	116		Clay	
10		116	125		Sand Med	Water
11		125	130		Clay	
12		130	134		Sand Med	
13		134	154.5		Clay	
14						
15						
16						
17						
18						
19						

Expected Water Bearing Zone

"For Geotechnical and Groundwater
 Pioneers of India"

[Signature]

Field Supervisor

Services Offered