

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- A-335

Date:- 24-02-2023

NAME OF SITE

Gram Panchayat- Kewal Rampur

BLOCK- Jalalabad


DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- KEWAL RAMPUR, BLOCK- JALALABAD, DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 24.Feb.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Clay kankar	
3.	8 - 17	9	Fine to Medium sand	Medium
4.	17 - 21	4	Clay kankar	
5.	21 - 30	9	Fine to Medium sand	Medium
6.	30 - 36	6	Clay kankar	
7.	36 - 46	10	Medium sand	Medium
8.	46 - 55	9	Clay kankar	
9.	55 - 61*	6	Fine to Medium sand	Medium
10.	61 - 64	3	Clay kankar	
11.	64 - 75*	11	Medium sand & kankar	Medium
12.	75 - 84	9	Clay kankar	
13.	84 - 87	3	Fine sand	Medium
14.	87 - 94	7	Clay kankar	
15.	94 - 121*	27	Medium sand & kankar	Medium
16.	121 - 125	4	Clay kankar	
17.	125 - 128	3	Sand & kankar	Medium
18.	128 - 140	12	Clay kankar	

Ground Water Survey Consultancy
Agra
U/Pt

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Ground Water Survey Consultancy

Rho a
 NI6 (SN)
 NS4(LN)
 LAT
 Logging vi Kewal
 Rampur block
 Jalalabad distt
 Sahajampur
 LOGGILGUP
 24 Feb 2023
 20:38
 utkarsh gupta
 (mvrind)

SP (m V)

