

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 20-10-23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- Vishavarey Environment Pvt Ltd Baleshwar

Village- Painiya Ramkisen Block- Baleshwar

District- Pr. b. Pr. Logging Depth- 150 mt

Drilling Depth- 150 mt Water Level- 4.5 mt APP

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-21	Chy kankar	
3	21-27	Medium Sand	Med + good
4	27-34	Chy kankar	
5	34-44	Medium Sand	Med + good
6	44-49	Chy kankar	
7	49-64	Medium Sand	Med + good
8	64-68	Chy kankar	
9	68-77	Medium Sand	Med + good
10	77-94	Chy kankar	
11	94-130	Medium Sand	Med + good
12	130-144	Chy kankar	
13	144-150	Chy kankar	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,

Third phase
 Lowering of Paimiya Ramkishan's scheme Distt - Pilibhat Block - Bankhara
 T.W. size - 200x150mm Lowering date - 21/10/23 discharge - 600 lpm / 150/140

200mm housing pipe

- 1- 6.00
- 2- 6.00
- 3- 6.00
- 4- 6.00
- 5- 6.10
- 6- 6.10
- 7- 6.10
- 42.00M

150mm plain pipe

- 1- 6.02 L
- 2- 6.01 L
- 3- 6.03 L
- 4- 6.03 L
- 5- 6.03 L
- 6- 6.01 L
- 7- 6.03 L
- 8- 6.02 L
- 9- 6.03 L
- 10- 6.03 L
- 11- 6.03 L
- 66.27M

150mm slotted pipe

- 1- 6.00 L
- 2- 6.00 L
- 3- 6.00 L
- 4- 6.00 L
- 5- 6.00 L
- 30.00M

Logging Report As -

49m — 64m — m Sand
 68m — 77m — m Sand — 6
 94m — 130m — M-Sand — 12+12

Plain pipe

6.02 ← 3.80 M L
 2.22 M L

200mm housing pipe — 42.00m
 200x150mm Reducer — 0.20m
 150mm plain pipe — 66.24m
 150mm slotted pipe — 30.00m
132.44m
 Reducer — 0.50m
131.94m

