

NCC Limited

(Formerly Nagarjuna Construction Company Limited)

Site Office:

H/o Pavan Upadhaya, Hotel Dream Palace,

Near BSNL Tower, Circuit House

District H.O. Kavindia Nagar Dhoose, P.O. Padrauna,

District Kushinagar U.P. - 274304

Starts chart As per Actual Tubewell Assembly lowered at Belwa urf Belwaniya SS

Block: MOTICHAK District Kushinagar Under Jal Jeevan Misson.

Type of Rig Machine - C. Rig Machine

Contractor Name - NCC Limited




Size of Bore - 600x500

Size of Assembly - 300x150

Depth Logged - 175

Date of Logging - 18-10-23




J.E. (E&M) DPM
 NCC Ltd.-Kushinagar

Abhay Pratap Singh
 TPI (M/S Meethaj)

J.E

A.E
 E.E, CD E&M UP JN (GRAMIN) GORAKHPUR

Office of the NCC Limited PADRAUNA Kushi Nagar Proposed
 Tubewell Assembly of Belwa up Belwariya Tubewell
 BLOCK MOTICHAK Under Jal Jivan Mission



Logging Date - 18/10/23
 Depth Logged - 175 mbsgl
 Bore Size - 600x500
 Drilling Depth -
 Discharge:-

S No.	DEPTH RANGE (MBSGL)	THICKNESS (M)	REMARKS
1.	30 - 40	10	
2.	50 - 65	15	
3.	99 - 111	12	
4.	115 - 118	03	
5.	122 - 133	11	

NOTE:-

D. P. K.
 JE (E/M)
 NCC LTD.

DPM
 Kushi Nagar

Abhay Pratap Singh
 TPI
 (M/s Medhaj)

JE

[Signature]
 AE
 EE, CD EAM UP JN (GRAMIN) GORAKHPUR

M/s Mahalaxmi Tube well



Rajnendra Nagar Pukhrayan Kanpur
9935299290mahalaxmitubewell@gmail.com

Geophysical Well Logging Report

Ref No – 10/192

Date -19/10/2023

Site Location : - Belwa Urff Belwaniya Motichauk Kushinagar
District : - Kushi Nagar
Logged Depth : - 175M BGL
Date of Logging : - 18/10/2023.
Types of Log : - S.P& N16, N-64 LAT
Logger used : - IGIS
Name of Agency : - NCC Limited Kushi Nagar

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	30	40	10		
02	50	65	15		
03	99	111	12		
04	115	118	03		
05	122	133	11	Fine to Medium Sand	All Good

Note- All zones are intermixed with fine bands of kankar.

M/s Mahalaxmi Tube Well

