

Hours of pumping from source, Tubewell 6.5 Hrs at Intermediate stage.
Ref: SWSM Guidelines vide letter number 1499/E-46/2021 dt 12-02-21

Rate of flow m³/Hr at intermediate stage

m ³ /Hr	LPM	Say	LPM
72	1200		1200

Year/Stage	Demand (KLD)	Operating hours
Initial Stage Year 2022	342	4.75
Intermediate Stage Year 2037	468	6.50
Ultimate Stage Year 2052	615	8.54

1.6 SOURCE OF WATER SUPPLY

Water discharge of 1200 LPM is required as per base year demand considering 6.5 hrs of pumping. Considering design flow at intermediate stage as 60% of safe yield from tubewell, minimum tubewell yield required is 2000 LPM

Tube well yield required $1200/0.6 = 2000$ LPM

Tube well yield required, roundedup	2000 LPM
-------------------------------------	----------

Ref: DISTRICT GROUND WATER BROCHURE OF SANT RAVIDASNAGAR DISTRICT, UP, compiled by CGWB 2012-13. Exploratory tubewells drilled up to 144m to 307m have shown yields up to 2065 & 2876 LPM. Considering probable long term depletion of yield, the 2876 LPM may be taken as characteristic maximum yield potential of tube wells in the district.

Hence we assume that required yield is available in this proposed area. Hence 1 tubewell with discharge rate of 2000 LPM has been considered for this project

1.7 REQUIREMENT OF TUBEWELLS & PUMPING HOURS

Table 17: Tubewell discharge calculation

Sn	Particulars	Stage / Year		
		2022	2037	2052
1	Population	5278	7230	9500
2	Rate of Water Supply LPCD	64.71	64.71	64.71
3	Daily Water Demand in KLD	342	468	615
4	Discharge of Tubewell Required in LPM	2000	2000	2000
5	No of Tubewell Required	1	1	1
6	Actual Pumping Hrs	4.75	6.5	8.54

Note: As per SWSM Guidelines vide letter number 1499/E-46/2021 dt 12-02-21, this project is proposed to be operated entirely on Solar power & panels shall be installed to meet power requirements for intermediate stage, subject to availability of the required land area. No state power utility connection is proposed in this project for pumps, actuators & control system.


The suggestion by CE (E&M) vide his letter no. 130/2062-0087/21 dtd. 270521 ; para 8 - that for lighting and fan load provision of 2 kW load in solar plant, alongwith provision of inverter and battery may be made - shall be assessed during detail engineering.



SI No.	Item of work	No.	L	B	H/D	Qty	Rate	Unit	Amount	Remarks
	MSERW Pipe slotted pipe as per IS 8110									
	100 MMØ slotted pipe					0	-	Rmt	-	
	150 MMØ slotted pipe					0	-	Rmt	-	
	200 MMØ slotted pipe					42	3,828.43	Rmt	1,60,794	
	300 MMØ slotted pipe					0	-	Rmt	-	
5	MS fittings such as clamp, bail plug, reducer, well cap, girder & support structure					1	32,249.79	LS	32,250	
6	MS fittings such as ring & centre guide					135	471.02	Rmt	63,587.70	Ref: 7.7 of IS 2800-2019
7	Lowering of above assembly with welding of parts complete in all respect with all required material, T&P, labour, etc. SOR NO. 4									As per RFP.
	Lowering up to 100 Mtr. Deep									
	100 MMØ MSERW Plane/Slotted Pipe					0	-	Rmt	-	
	150 MMØ MSERW Plane/Slotted Pipe					0	-	Rmt	-	
	200 MMØ MSERW Plane/Slotted Pipe					46	389.45	Rmt	17,914.70	
	300 MMØ MSERW Plain/Slotted Pipe					54	489.31	Rmt	26,422.74	
	Lowering from 101 Mtr. To 200 Mtr. Deep									
	150 MMØ MSERW Plane/Slotted Pipe deep 101 to 200 m					0	-	Rmt	-	
	200 MMØ MSERW Plane/Slotted Pipe deep 101 to 200 m					35	589.97	Rmt	20,648.95	
	300 MMØ MSERW Plain/Slotted Pipe deep 101 to 200 m					0	-	Rmt	-	
	Lowering from 201 Mtr. To 300 Mtr. Deep									
	150 MMØ MSERW Plane/Slotted Pipe deep 201 to 300 m					0	-	Rmt	-	
	200 MMØ MSERW Plane/Slotted Pipe deep 201 to 300 m					0	-	Rmt	-	
	300 MMØ MSERW Plane/Slotted Pipe deep 201 to 300 m					0	-	Rmt	-	
	Lowering from 301 Mtr. To 400 Mtr. Deep & above									
	150 MMØ MSERW Plane/Slotted Pipe 301 to 400 m Deep and above					0	-	Rmt	-	
	200 MMØ MSERW Plane/Slotted Pipe 301 to 400 m Deep and above					0	-	Rmt	-	
	300 MMØ MSERW Plane/Slotted Pipe 301 to 400 m Deep and above					0	-	Rmt	-	



Banault T/w, Block - Aurai





Aqua Xplore

(Groundwater Assessment & Allied Services)

243/5, New Colony Jiyamau, Hazratganj, Lucknow – 226001

Mob. 9918202546 / 9889323322, Email-aquaxploreko@gmail.com

Advisor- Dr. R. A. Yadav, ex- Manager (Groundwater), U. P. Jal Nigam

Ref 301 - B / AX - 2024

Date 01.03.2024

Geophysical Borehole Logging Report

Name of the site : Banauli, Block- Aurai

District : Sant Ravidas Nagar

Date : 01.03.2024

Depth logged : 125.0 mbgl

Depth drilled : 150.0 mbgl – as reported Rmf- 12.0 Ohm-m Rw-14.0 Ohm-m

Logger used : UPTRON make

Presence : Rep. of M/S Welspun Enterprises Limited, Sant Ravidas Nagar, U.P.

Based on the interpretation of geophysical logs, following information may be deciphered, particularly with respect to salinity of the formation water;

Sl.No.	Depth range(mbgl)	Thickness(m)	Remarks
1	37.0–41.0	4.0	Good all
2	45.0–55.0	10.0	
3	58.0–65.0	7.0	
4	70.0–80.0	10.0	
5	85.0–89.0	4.0	
6	104.0–109.0	5.0	
7	118.0–122.0	4.0	

Note. All zones are intermixed with kankar. Sl. No. 7 is fine sand.

for Aqua Xplore

CC;

1. Welspun Enterprises Limited, Sant Ravidas Nagar, U.P.

4-3-024

DD-150-110

बनौली
डौराई
मण्डली

