

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 10.4.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency Wood Hill Infrastructure Firozabad SRG, Chand Machu

Village Pilakhanu Block Nakud

District Saharanpur Logging Depth 165 mb

Drilling Depth 172 mb Water Level.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	fine sand	
3	10 - 15	clay kanker	
4	15 - 24	Sandy clay	
5	24 - 40	clay kanker	
6	40 - 70'	Medium Sand	Medium
7	70 - 77	clay kanker	
8	77 - 92'	Med Sand + kank	Medium
9	92 - 98	clay kanker	
10	98 - 125'	Med Sand + tan	Medium
11	125 - 130	clay kanker	
12	130 - 138	kanker	
13	138 - 165	clay kanker	
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.