



Contract No. M/S. W/S/2023



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Sakharjung Enclave, New Delhi - 110 029
 Mobile : 9818 988 824, 9818 007 038
 E-mail : srikanthchukka.c23@gmail.com, ravikanth44@yahoo.com

M. KUSUJIA
 P. R. Khan G. P. O.

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Date : ...1...03...2023

Tubewell No. :

Village : VISANPUR

Block : SIKANDRAPADA

District : BULAND SHAHR, U.P

Depth in Metres	Expected Lithology	Expected Water Quality
0-3m	Surface soil	
3-13	Sandy clay	
13-34	medium sand	good
34-38	Sandy clay	
38-70	medium sand	good
70-81	clay	
81-85	medium sand	good
85-99	clay	
99-110	medium sand	good
110-131	clay	
131-134	sandy clay	
134-150	clay kankar	

For Global Groundwater Consultants

(Signature)
 M. RAVI KANTH
 1/3/2023

⊗ EXPECTED WATER ZONE
 ▼ WATER LEVEL : ...13... METRES

Consulting Geologists, Geophysicists & Ground Water Specialists

Scanned by CamScanner



Visanpur
 Sikandra bad
 Buland Sahar

Date: 1/3/2023

mls.wels.pun

Kusawa
 Kishan Lal
 GGWC

Depth in m	SP	SN in Ohms	in Feet	Depth in m	SP	SN in ohm	in Feet
0			0.0	41	59	5.0	134.5
1			3.3	42	61	4.9	137.8
2			6.6	43	64	4.7	141.0
3	69	2.9	9.8	44	62	5.0	144.3
4	64	3.4	13.1	45	62	4.9	147.6
5	66	3.9	16.4	46	61	4.7	150.9
6	69	3.9	19.7	47	59	4.5	154.2
7	71	3.9	23.0	48	54	4.9	157.4
8	72	3.8	26.2	49	52	5.0	160.7
9	71	3.7	29.5	50	51	5.0	164.0
10	76	3.8	32.8	51	56	5.0	167.3
11	74	3.9	36.1	52	58	5.1	170.6
12	78	4.0	39.4	53	59	5.1	173.8
13	79	4.1	42.6	54	61	5.1	177.1
14	74	4.4	45.9	55	66	5.0	180.4
15	78	4.1	49.2	56	62	4.8	183.7
16	79	4.6	52.5	57	60	4.9	187.0
17	81	4.8	55.8	58	61	5.2	190.2
18	84	4.8	59.0	59	66	5.0	193.5
19	85	4.6	62.3	60	64	4.8	196.8
20	84	4.6	65.6	61	62	4.8	200.1
21	91	5.1	68.9	62	61	5.2	203.4
22	94	5.2	72.2	63	62	5.2	206.8
23	96	5.0	75.4	64	64	4.8	209.9
24	94	5.3	78.7	65	69	4.9	213.2
25	89	5.2	82.0	66	71	4.5	216.5
26	86	5.2	85.3	67	74	5.4	219.8
27	85	5.4	88.6	68	78	5.2	223.0
28	89	5.5	91.8	69	79	4.9	226.3
29	86	4.8	95.1	70	81	3.5	229.6
30	84	5.0	98.4	71	81	2.5	232.9
31	82	4.2	101.7	72	84	2.2	236.2
32	84	4.7	105.0	73	82	2.0	239.4
33	86	4.4	108.2	74	81	2.0	242.7
34	89	4.1	111.5	75	86	2.4	246.0
35	90	2.9	114.8	76	89	2.1	249.3
36	91	3.2	118.1	77	91	1.7	252.6
37	93	3.6	121.4	78	94	1.8	255.8
38	94	4.8	124.6	79	92	1.8	259.1
39	92	5.0	127.9	80	91	2.2	262.4
40	91	5.1	131.2	81	90	3.3	265.7



GGWC

Depth in m	SP	SN		in Feet	Depth in m	SP	SN		in Feet
82	79	4.3		269.0	123	42	1.4		403.44
83	62	4.3		272.2	124	41	1.3		406.72
84	76	4.3		275.5	125	46	1.2		410
85	84	4.2		278.8	126	49	1.6		413.28
86	85	2.4		282.1	127	43	2.1		416.56
87	95	2.2		285.4	128	46	2.2		419.84
88	96	1.4		288.6	129	35	2.1		423.12
89	92	1.1		291.9	130	34	1.9		426.4
90	91	1.0		295.2	131	33	2.6	1	429.68
91	99	1.2		298.5	132	34	3.3	5.5	432.96
92	98	1.1		301.8	133	32	3.8		436.24
93	91	1.1		305.0	134	36	3.6	1	439.52
94	94	1.2		308.3	135	33	1.6		442.8
95	92	1.4		311.6	136	41	1.5		446.08
96	91	1.5		314.9	137	42	1.4		449.36
97	96	1.8		318.2	138	41	1.5		452.64
98	98	2.2		321.4	139	42	1.6		455.92
99	99	3.0		324.7	140	41	1.5		459.2
100	92	4.2		328.0	141	42	2.4		462.48
101	91	4.8		331.3	142	41	2.1		465.76
102	96	5.1		334.6	143	41	2.1		469.04
103	93	5.1		337.8	144	46	2.2		472.32
104	99	5.2		341.1	145	43	1.5		475.6
105	90	4.8		344.4	146	48	1.2		478.88
106	92	4.7		347.7	147	42	1.1		482.16
107	90	4.7		351.0	148	41	3.6		485.44
108	89	3.6		354.2	149	46	1.4		488.72
109	89	2.6		357.5	150	42	1.3		492
110	47	2.7		360.8	151				495.28
111	48	2.3		364.1	152				498.56
112	49	1.8		367.4	153				501.84
113	46	2.1		370.6	154				505.12
114	44	2.1		373.9	155				508.4
115	42	1.8		377.2	156				511.68
116	41	1.7		380.5	157				514.96
117	42	1.6		383.8	158				518.24
118	41	1.6		387.0	159				521.52
119	43	2.1		390.3	160				524.8
120	44	2.2		393.6	161				528.08
121	42	2.3		396.9	162				531.36
122	41	1.9		400.2	163				534.64