


NAME OF THE DISTRICT- <u>Gorakhpur</u>	TYPE OF RIG M/C-
NAME OF THE BLOCK- <u>Saidat Nagar</u>	SIZE OF BORE- <u>550 X 500 mm</u>
NAME OF THE GRAM PANCHAYAT- <u>Amkol</u>	STATIC WATER LEVEL-
NAME OF THE VILLAGE-	J.E Incharge <u>Hanuman Prasad</u> A.E Incharge <u>Barbar Yadav</u>

DEPTH B.G.L. IN METER	BORING CHART	STRATA	EXECUTED ASSEMBLY	ASSEMBLY DETAILS
0.0 m			A.G.L = 0.5 m	200 mm Dia Housing Pipe A.G.L = 0.500 m
10.5 m		Sandy clay Soft clay		200 mm Dia Housing Pipe 0.0 m to 35.67 m 200 mm Dia Reducer 35.67 m to 35.87 m 150 mm Dia Blind pipe 35.87 m to 70.5 m
20.2 m		Medium Sand		150 mm Dia Slotted pipe 70.5 m to 76.57 m 150 mm Dia Blind pipe 76.57 m to 82.53 m 150 mm Dia Slotted pipe 82.53 m to 91.59 m 150 mm Dia Blind pipe 91.59 m to 103.69 m 150 mm Dia Slotted pipe 103.69 m to 106.69 m 150 mm Dia Blind pipe 106.69 m to 112.74 m
36.7 m		clay		
40.5 m		Medium Sand		
54.2 m		clay + sand + kankar		
70.1 m		Medium Sand		
77.4 m		clay + kankar		
82.1 m		Medium Sand		
92.6 m		clay		
98.5 m		Medium Sand		
120.6 m		clay		
145 m				
SOUND TEST-			Total Assembly = 112.74 m + A.G.L (m) = 113.24 m	
VERTICALITY TEST-			ABSTRACT	
			1. Drilling Started-	
			2. Drilling Completed/Lowering-	
			3. Drilling Depth (m)- 145 m	
			4. Assembly Lowered (m)- 113.24 m	
			5. Housing Pipe (m)- 35.17 m	
			6. Plain Pipe (m)- 58.74 m	
			7. Slotted Pipe (m)- 18.13 m	
			8. Reducer (m)- 0.20 m	
			LOGGING REPORT	
			1- 20.0 - 36.0 m = 16 m	
			2- 40.0 - 54.0 m = 14 m	
			3- 70.0 - 77.0 m = 07 m	
			4- 82.0 - 92.0 m = 10 m	
			5- 98.0 - 120.0 m = 22 m	
			6-	
			7-	
			8-	
			9-	
			10-	



<u>Amol</u>	<u>[Signature]</u>	<u>[Signature]</u>
NCC LTD	J.E & A.E	P.M./C./P.I.A
		E.E