



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029

Mobile : 9818 888 824, 9818 007 038

E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

m/s. Mayno Infra

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : 24.9.2022

Village : SALAGAMA KHIDRABAD

Block : JAHNGERABAD

District : BULAND SAHAR, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface soil	
3-11	Fine sand	
11-19 [⊗]	medium sand	Good
19-23	clay	
23-69 [⊗]	medium sand	Good
69-74	Sandy clay	
74-84	clay	
84-91 [⊗]	Fine sand	Good
91-94	clay	
94-99 [⊗]	Fine sand	Good
99-114 [⊗]	medium sand	Good
114-119	clay	
119-122 [⊗]	Fine sand	Good
122-153	Sandy clay kanker.	

For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE

▼ WATER LEVEL :11..... METRES

M. RAJ KANTH

2022/09/24 16:29