



contracts: m/s. welspun



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9818 888 824, 9818 007 038
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

M/s. Shivam

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : 13.2.2023

Village : GOUILA

Block : KHURZA

District : Doland Sahar, O.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface Soil	
3-14	medium sand	good
14-16	Sandy clay	
16-28	medium sand	good
28-29	clay	
29-35	medium sand	good
35-38	clay	
38-51	medium sand	good
51-58	clay	
58-63	medium sand	good
63-67	Sandy clay	
67-78	coarse sand	good
78-85	Sandy clay	
85-91	medium sand	good
91-113	clay kankar	
113-120	medium sand	good
120-154	clay kankar	

For Global Groundwater Consultants

- ⊗ EXPECTED WATER ZONE
- ▼ WATER LEVEL : ...4..... METRES

(Signature)
13/2/2023

Consulting Geologists, Geophysists & Ground Water Specialists

Scanned by CamScanner