

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTOLOGGING REPORT**

Ref No:-B-2747

Date:- 26-12-2023

NAME OF SITE

GRAM PANCHAYAT- Amanpur BLOCK- Tilhar DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- AMANPUR, BLOCK- TILHAR, DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 138 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 26.Dec.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

| S.No. | Depth range(m) | Thickness(m) | Lithology | Expected Water Quality |
|-------|----------------|--------------|------------------------|------------------------|
| 1. | 0 - 5 | 5 | Surface soil | |
| 2. | 5 - 20 | 15 | Clay kankar | |
| 3. | 20 - 25 | 5 | Fine sand | |
| 4. | 25 - 30 | 5 | Clay kankar | |
| 5. | 30 - 40 | 10 | Fine to Medium sand | Medium |
| 6. | 40 - 50 | 10 | Clay kankar | |
| 7. | 50 - 67* | 17 | Medium sand | Medium |
| 8. | 67 - 72 | 5 | Clay kankar | |
| 9. | 72 - 93* | 21 | Medium sand | Medium |
| 10. | 93 - 99 | 6 | Clay kankar | |
| 11. | 99 - 111* | 12 | Fine to Med sand & kan | Medium |
| 12. | 111 - 118 | 7 | Clay kankar | |
| 13. | 118 - 135* | 17 | Fine to Medium sand | Medium |
| 14. | 135 - 138 | 3 | Clay kankar | |

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



B Rio a
 N16 (SN)
 N64 (LN)
 LAT

Logging Details
 Geophysical Interpretation
 From: The Dip
 29 September
 97 (2007) 22
 21 (2007) 22
 21 (2007) 22
 21 (2007) 22
 21 (2007) 22

Logger's Name: IGIS/01/21-22

B Sp (m V)
 DHP/L2
 Logger Owned by:
 GROUND WATER SURVEY CONSULTANCY
 AGRA, UP, India

