

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-A-512

Date:- 15-05-2023

NAME OF SITE

GRAM PANCHAYAT- Kanpari

BLOCK- Bilsanda

DISTT- Pilibhit

NAME OF AGENCY

M/s Vishvaraj Environment Pvt. Ltd.




GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- KANPARI, BLOCK- BILSANDA, DISTT.- PILIBHIT
UNDER
JAL JIVAN MISSION


Introduction :

A Deep bore hole was drilled 150 mtrs. depth. and Logged depth 150 mtrs. at above site. Was drilled by M/s Vishvaraj Environment Pvt. Ltd.

On the request of M/s Vishvaraj Environment Pvt. Ltd. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 15.May.2023.


Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 9	4	Fine sand	
3.	9 - 15	6	Clay kankar	
4.	15 - 25	10	Medium sand	Med to Good
5.	25 - 30	5	Clay kankar	
6.	30 - 41	11	Medium sand	Med to Good
7.	41 - 45	4	Clay kankar	
8.	45 - 59*	14	Medium sand	Med to Good
9.	59 - 62	3	Clay kankar	
10.	62 - 70*	8	Medium sand	Med to Good
11.	70 - 82	12	Clay kankar	
12.	82 - 89*	7	Medium sand	Med to Good
13.	89 - 96	7	Clay kankar	
14.	96 - 123*	27	Medium sand	Med to Good
15.	123 - 130	7	Clay kankar	
16.	130 - 132	2	Fine sand	Med to Good
17.	132 - 137	5	Clay kankar	
18.	137 - 142	5	Fine sand	Med to Good
19.	142 - 145	3	Clay kankar	
20.	145 - 150*	5	Medium sand	Med to Good



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Ground Water Survey Consultancy

Rho a
 N 16(SN)
 N 64(LN)
 LAT

Logger Site No.:
 IGIS/S/01/21-22

Logger Model:
 DMPL-2

Logger Owned by:
 GROUND WATER SURVEY CONSULTANCY AGRA, UP, India

CENTER:
 NAME OF GEOMAGNETIC STATION:
 ELEVATION DATA POINT:
 LOG No.:
 UT COORDINATE:
 DATE:
 TIME (HH:MM:SS):
 YEAR:
 OPERATOR:
 UNDER SUPERVISOR:
 WEA. DATA:

