

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- 670

Date:- 09-01-2023

NAME OF SITE

Gram Panchayat- Brah Mohabbatpur BLOCK- Tilhar DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BRAH MOHABBATPUR, BLOCK- TILHAR, DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION


Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 09.Jan.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

| S.No. | Depth range(m) | Thickness(m) | Lithology | Expected Water Quality |
|-------|----------------|--------------|---------------------|------------------------|
| 1. | 0 - 5 | 5 | Surface soil | |
| 2. | 5 - 10 | 5 | Clay | |
| 3. | 10 - 12 | 2 | Fine sand | |
| 4. | 12 - 17 | 5 | Clay kankar | |
| 5. | 17 - 29 | 12 | Fine to Medium sand | Medium |
| 6. | 29 - 33 | 4 | Clay kankar | |
| 7. | 33 - 48 | 15 | Medium sand | Medium |
| 8. | 48 - 52 | 4 | Clay kankar | |
| 9. | 52 - 83* | 31 | Medium sand | Medium |
| 10. | 83 - 88 | 5 | Clay kankar | |
| 11. | 88 - 94* | 6 | Medium sand | Medium |
| 12. | 94 - 100 | 6 | Clay kankar | |
| 13. | 100 - 128* | 28 | Medium sand | Medium |
| 14. | 128 - 140 | 12 | Sandy clay | |



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Page 1
 NIS SN
 MS400
 LAT
 Logging Details
 Date: 11/11/2011
 Time: 10:00 AM
 Location: [illegible]
 Project: [illegible]
 Operator: [illegible]

Page 2 of 2
 16S/S03/21-22
 Logger Model: SP (m V)
 DIAPL-2
 Logger Channel: [illegible]
 Ground Water Survey
 Consultancy - Agri
 India

