

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No-47 158

Date:- 21-04-2023

NAME OF SITE

GRAM PANCHAYAT- Baleli

BLOCK- Dadrol

DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



Electrical Well Logging, Geophysical Resistivity Survey, Ground Water Investigations
HIT A-Three Nagar Colony, Pirobad Road, Agra-282006
(Ph): 9412760827, 9794625420, 9761163000, Email: gwscc_agra@yahoo.com

ISO : 9001 : 2015

Ground Water Survey Consultancy

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BALELI, BLOCK- DADROL,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 120 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 21.April.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Kankar	
3.	10 - 15	5	Clay kankar	
4.	15 - 18	3	Fine sand	
5.	18 - 21	3	Clay kankar	
6.	21 - 30	9	Fine to Medium sand	Good
7.	30 - 35	5	Clay kankar	
8.	35 - 57	22	Medium sand	Good
9.	57 - 62	5	Clay kankar	
10.	62 - 70	8	Sand & kankar	Good
11.	70 - 77	7	Clay kankar	
12.	77 - 98*	21	Medium sand	Good
13.	98 - 103	5	Clay kankar	
14.	103 - 120*	17	Medium sand & kankar	Good


Ground Water Survey Consultancy

Agra
J 1/21

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho 1
 NIS (SN)
 NS4(LN)
 LAT

Logging Details:
 000 71 54 2004
 000 00 00 00 00
 00 00 00 00 00
 00 00 00 00 00
 00 00 00 00 00
 00 00 00 00 00
 00 00 00 00 00

Logger Site:
 IGIS/S/02/22-23

Logger Model:
 SP (m V)
 DMPL-2
 Logger Dates for:
 GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, UP, INDIA

