




Contact No. 011-26128291



GLOBAL GROUND WATER CONSULTANTS
84-B Floor, Hansraj Park, Saket, New Delhi - 110 029
Mobile : 0810 890 824, 9018 007 038
E-mail : arkerthchaika-22@gamil.com, revikant44@yahoo.com

M/s. Shivam

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. : _____ Date : 24/2/2023

Village : FARAND JAMALPUR
Block : KHURD
District : BULAND SHAHAR

Depth in Metres	Expected Lithology	Expected Water Quality
0-3m	Surface Soil	
3-12	clay	
12-26	Fine Sand	Good
26-48	medium sand	Good
48-54	clay	
54-58	Fine Sand	Good
58-62	clay	
62-73	Fine Sand	Good
73-87	clay	
87-95	medium sand	Good
95-116	clay	
116-121	medium to fine sand	Good
121-150	clay kankar	

⊗ EXPECTED WATER ZONE

▽ WATER LEVEL : 12 METRES

For Global Groundwater Consultants

(Signature)
M. RAJ KANTH
24/2/2023

Consulting Geologists, Geophysicists & Ground Water Specialists