



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9618 888 824, 9618 007 038
E-mail : srkanthchukka.c23@gmail.com, ravikanth44@yahoo.com

Company: M/S. Welspan

M/S. Shivam

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : 2.5.2023

Village : Bagla poothri

Block :

District : Buland shahar, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface Soil	
3-19	Fine Sand	
19-26	clay	
26-43	medium sand	good
43-51	Sandy clay	
51-58	Fine sand	good
58-61	clay	
61-71	medium sand	good
71-81	clay	
81-103	medium sand	good
103-106	clay	
106-115	medium sand	good
115-126	clay	
126-133	Sandy clay	
133-141	clay kankar	

For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE

▼ WATER LEVEL : 16 METRES

M. Ravi Kanth
M. RAVI KANTH
2/5/2023