



Contract: m/s. wells pun



**GLOBAL GROUND WATER CONSULTANTS**

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029  
Mobile : 9818 888 824, 9818 007 038  
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

Mr. Preetam

**GEOPHYSICAL ELECTRICAL LOGGING REPORT AT**

Tubewell No. : .....

Date : 24.4.2023

Village : KOTA

Block : GULAOTHI

District : BULANDSAHAR, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface Soil	
3-16	Sandy clay	
16-34	medium sand	Good
34-43	Sandy clay	
43-56	medium sand	Good
56-63	clay	
63-72	Fine sand	Good
72-81	clay	
81-88	medium sand	Good
88-114	clay	
114-122	medium sand	Good
122-125	clay	
125-131	Fine sand	Good
131-141	clay	
141-149	Fine sand	Good
149-150	clay	

For Global Groundwater Consultants

- ⊗ EXPECTED WATER ZONE
- ▽ WATER LEVEL : .....9..... METRES

*(Signature)*  
M. Ravi Kant  
24/4/2023

Consulting Geologists, Geophysicists & Ground Water Specialists

Scanned by CamScanner



Kota  
Golaothi, Bolandshah

wells pm

Location:

Date: 24/4/2023

GGWC

Depth in m	SP	SN in Ohms	in Feet	Depth in m	SP	SN in ohm	in Feet
0			0.0	41	60	3.0	134.5
1			3.3	42	61	3.8	137.8
2			6.6	43	66	4.5	141.0
3	13	5.6	9.8	44	64	4.2	144.3
4	14	6.3	13.1	45	62	4.9	147.6
5	16	3.2	16.4	46	61	4.6	150.9
6	18	3.4	19.7	47	60	5.0	154.2
7	16	3.2	23.0	48	64	4.9	157.4
8	19	2.5	26.2	49	68	4.9	160.7
9	20	2.2	29.5	50	69	4.9	164.0
10	21	3.1	32.8	51	71	4.9	167.3
11	26	5.7	36.1	52	76	4.9	170.6
12	28	4.3	39.4	53	72	4.2	173.8
13	26	2.4	42.6	54	71	4.6	177.1
14	28	2.3	45.9	55	76	4.6	180.4
15	26	2.8	49.2	56	74	4.1	183.7
16	24	3.2	52.5	57	72	2.2	187.0
17	26	4.3	55.8	58	58	1.8	190.2
18	28	4.4	59.0	59	61	1.2	193.5
19	29	4.2	62.3	60	64	1.4	196.8
20	26	4.4	65.6	61	62	1.6	200.1
21	28	4.3	68.9	62	61	1.9	203.4
22	29	3.3	72.2	63	66	2.6	206.6
23	26	4.5	75.4	64	62	2.2	209.9
24	24	4.8	78.7	65	61	2.2	213.2
25	29	5.1	82.0	66	64	2.8	216.5
26	34	4.5	85.3	67	62	2.2	219.8
27	32	4.1	88.6	68	66	2.8	223.0
28	32	4.5	91.8	69	64	3.0	226.3
29	31	4.1	95.1	70	62	2.2	229.6
30	54	4.3	98.4	71	61	2.3	232.9
31	56	4.6	101.7	72	66	2.5	236.2
32	58	4.4	105.0	73	64	2.0	239.4
33	59	4.1	108.2	74	69	1.9	242.7
34	61	3.4	111.5	75	71	1.2	246.0
35	66	2.8	114.8	76	68	1.4	249.3
36	64	2.9	118.1	77	61	1.3	252.6
37	62	3.1	121.4	78	66	1.3	255.8
38	61	2.2	124.6	79	64	1.4	259.1
39	62	2.3	127.9	80	62	1.6	262.4
40	61	2.4	131.2	81	61	2.1	265.7

proctan





GGWC

Depth in m	SP	SN		in Feet	Depth in m	SP	SN		in Feet
82	64	3.4	MS	269.0	123	46	1.9	FS	403.44
83	62	3.8		272.2	124	48	2.2		406.72
84	61	4.3		275.5	125	46	2.6		410
85	66	4.5		278.8	126	42	2.6		413.28
86	64	4.5		282.1	127	41	2.7		416.56
87	68	4.1		285.4	128	46	3.0		419.84
88	69	3.8		288.6	129	49	3.2		423.12
89	62	2.0		291.9	130	56	3.9		426.4
90	66	1.9		295.2	131	59	2.4		429.68
91	59	2.0		298.5	132	63	1.2		432.96
92	58	1.9	301.8	133	64	2.2	436.24		
93	54	1.6	305.0	134	62	3.2	439.52		
94	52	1.2	308.3	135	61	1.2	442.8		
95	51	0.6	311.6	136	62	1.5	446.08		
96	23	0.5	314.9	137	61	1.5	449.36		
97	26	0.8	318.2	138	66	1.8	452.64		
98	24	0.9	321.4	139	64	2.1	455.92		
99	22	0.9	324.7	140	68	2.6	459.2		
100	21	0.9	328.0	141	62	3.0	462.48		
101	24	0.9	331.3	142	61	3.5	465.76		
102	26	0.8	334.6	143	64	3.3	469.04		
103	24	0.8	337.8	144	62	3.4	472.32		
104	26	1.0	341.1	145	61	2.2	475.6		
105	25	1.5	344.4	146	66	2.2	478.88		
106	24	1.2	347.7	147	64	2.8	482.16		
107	22	1.4	351.0	148	65	2.8	485.44		
108	26	1.6	354.2	149	62	2.9	488.72		
109	28	1.6	357.5	150	61	3.5	492		
110	29	1.8	360.8	151			495.28		
111	31	1.6	364.1	152			498.56		
112	41	1.5	367.4	153			501.84		
113	46	1.8	370.6	154			505.12		
114	45	2.6	373.9	155			508.4		
115	48	3.0	377.2	156			511.68		
116	46	3.5	380.5	157			514.96		
117	44	3.2	383.8	158			518.24		
118	42	3.8	387.0	159			521.52		
119	41	3.8	390.3	160			524.8		
120	42	3.2	393.6	161			528.08		
121	46	4.1	396.9	162			531.36		
122	44	3.5	400.2	163			534.64		

