



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9818 888 824, 9818 007 038
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

m/s. welspon

Mr. KUSUWA

Mr. KISHAN GOPAL

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :

Date : 26.4.2023

Village : KAPSAIPUR

Block : UNCHAGAON

District : BULAND SAHAR, U.P

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Subsoil	
3-15	medium sand	
15-54	coarse sand	good
54-56	medium sand	good
56-68	coarse sand	good
68-71	medium sand	good
71-99	coarse sand	good
99-120	coarse to medium sand	good
120-132	sandy clay	
132-141	clayanker	
141-146	clay	

For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE
▽ WATER LEVEL :15..... METRES

Signature
M. RAJESH
26/4/2023