

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTOLOGGING REPORT**

Ref No:-B- 1225

Date:- 05-07-2023

NAME OF SITE

GRAM PANCHAYAT- Kaberpur Jhotupur BLOCK- Nigohi DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- KABEERPUR JHOTUPUR, BLOCK- NIGOHI,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION


Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 115 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 05.July.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Fine sand	
3.	10 - 13	3	Clay kankar	
4.	13 - 18	5	Fine sand	Med to Good
5.	18 - 30	12	Clay kankar	
6.	30 - 36	6	Fine to Medium sand	Med to Good
7.	36 - 43	7	Clay kankar	
8.	43 - 60*	17	Medium sand & kankar	Med to Good
9.	60 - 66	6	Clay kankar	
10.	66 - 74*	8	Fine to Medium sand	Med to Good
11.	74 - 84	10	Clay kankar	
12.	84 - 105*	21	Medium sand	Med to Good
13.	105 - 110	5	Clay kankar	
14.	110 - 115	5	Sandy clay	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Ground Water Survey Consultancy

Rho a
 NI6 (SR)
 NI6Q(N)
 LAT

Logging Details:
 Date of operation:
 Location:
 Name of Consultant:
 Date of 2023:
 15.11.23
 Sheet No: 1/2

Log No:
 RGS/SO/23-24

Logger Name:
 SP (m V)

DAPI-2
 Logger Code No:
 Ground Water
 Survey/Consultancy
 Agra UP India

