



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 18/06/2024

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- Welspun Kutchha Industries
 Village - Kotla Block- Danapur
 District- Bulandshahr Logging Depth- 138 mtr
 Drilling Depth- 140 mtr Water Level- 9 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 24	clay Kankar	
3	24 - 40	Fine to med. Sand	medium
4	40 - 54	clay Kankar	
5	54 - 71*	medium Sand	medium
6	71 - 75	clay Kankar	
7	75 - 87*	medium Sand	medium
8	87 - 94	clay Kankar	
9	94 - 98	Fine Sand	medium
10	98 - 105	clay Kankar	
11	105 - 118*	medium Sand	medium
12	118 - 138	clay Kankar	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

(Handwritten signature)

Geophysicist

