

GEO – TECHNICAL CONSULTANT

(Division of MACHTECH)

Plot no. 61 Vikaskung, Near Tower, Dibiyapur – 206244, District – Auraiya, Uttar Pradesh (India)

E-mail: machtechtools55@gmail.com, Mobile Number: 9265018387

Ref: MTL/WL/23-24/466

Date: 08.09.2023

REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

A deep borehole was drilled by working agency M/s. PMPL - BRCCPL (JV) as a part of their scope of work of development of Tubewell under Jal Jeevan Mission Project of SWSM, MTL conducted a Geophysical Continuous logging in the above borehole.

| Village Name | KARIYAMAU |
|----------------|---|
| Block | HASWA |
| District | FATEHPUR, U.P. |
| Drilling depth | 180 MBGL |
| Logged Depth | 158.1 Mtr BGL |
| Type of Log | Continuous well logger (SP, N16 (SN), N64 (LN) & LAT) |
| Machine Used | IGIS |
| Logging Date | 07.09.2023 |

The following aquifer zones have been deciphered with the help of logging machine.

| Sr. No. | Depth Range (mtr BGL) | Thickness (mtr) | Expected Quality |
|---------|-----------------------|--------------------|------------------|
| 1 | 35 – 40 | 5 | Good to Moderate |
| 2 | 46 – 50 | 4 | Good |
| 3 | 52 – 55 | 3 | Good |
| 4 | 57 – 60 | 3 | Good |
| 5 | 101 – 104 | 3 | Good to Moderate |
| 6 | 111 – 115 | 4 | Good |
| 7 | 134 – 137 | 3 | Good to Moderate |
| 8 | 146 – 149 | 3 | Good |

Rw - 21.8 Ohm mtr and Rm - 48.2 Ohm mtr

Note: Below 149 MBGL no proper granular zone encountered till log depth.

Anand Kumar

(Hydrogeologist)

For Geo-Technical Consultant,

Authorised Signatory