


NAME OF THE DISTRICT- Gorakhpur
 NAME OF THE BLOCK- Piprauli
 NAME OF THE GRAM PANCHAYAT- Deipari
 NAME OF THE VILLAGE-
 TYPE OF RIG M/C-
 SIZE OF BORE- 300 X 150 mm
 STATIC WATER LEVEL-
 J.E Incharge Nandu Bhusari A.E Incharge Barbari Yadav

DEPTH B.G.L. IN METER | BORING CHART | STRATA | EXECUTED ASSEMBLY | ASSEMBLY DETAILS

DEPTH B.G.L. IN METER	BORING CHART	STRATA	EXECUTED ASSEMBLY	ASSEMBLY DETAILS
0.0 m				300 mm Dia Housing Pipe A.G.L. = 0.50 m
3.2 m		Clay		300 mm Dia Housing Pipe 0.0 m to 35.64 m
10.5 m		Sandy Clay		300 mm Dia Reducer 35.64 m to 35.84 m
20.2 m		Clay + Coarse Sand + kankar		150 mm Dia Blind pipe 35.84 m to 64.88 m
30.6 m		Medium Sand + kankar		150 mm Dia Slotted pipe 64.88 m to 70.88 m
34.4 m		Soft clay		150 mm Dia Blind pipe 70.88 m to 76.9 m
		Medium Sand + kankar		150 mm Dia Slotted pipe 76.9 m to 91.93 m
53.7 m		Sandy clay		150 mm Dia Blind pipe 91.93 m to 114.5 m
64.1 m		Fine Sand + kankar		150 mm Dia Slotted pipe 114.50 m to 117.52 m
72.5 m		Clay + kankar		150 mm Dia Blind pipe 117.52 m to 123.55 m
76.2 m		Medium Sand + kankar		
94.7 m		Coarse Sand + kankar		
106.1 m		Very fine Sand		
114.1 m		Very soft clay		
118.3 m		Very fine Sand		
130.5 m		Clay + kankar		
134.7 m		Very fine Sand		
152 m		Hard Clay		



Total Assembly = 123.55 m + A.G.L. (m) = 124.05 m

ABSTRACT

1. Drilling Started-
2. Drilling Completed/Lowering-
3. Drilling Depth (m)- 152 m
4. Assembly Lowered (m)- 124.05 m
5. Housing Pipe (m)- 36.14 m
6. Plain Pipe (m)- 63.66 m
7. Slotted Pipe (m)- 24.05 m
8. Reducer (m)- 0.20 m

LOGGING REPORT

1. 20.0 - 30.0 m = 10.0 m
2. 34.0 - 53.0 m = 19.0 m
3. 64.0 - 72.0 m = 08.0 m
4. 76.0 - 94.0 m = 18.0 m
5. 106.0 - 110.0 m = 04.0 m
6. 114.0 - 118.0 m = 04.0 m
7. 130.0 - 134.0 m = 04.0 m
- 8.
- 9.
- 10.

SOUND TEST-
 VERTICALITY TEST-

 NCC LTD | J.E & A.E | P.M.C/T.P.I.A | E.E