

**GROUND WATER SURVEY CONSULTANCY**  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL  
ELECTOLOGGING REPORT**

Ref No:-B-485

Date:- 14-05-2023

**NAME OF SITE**

GRAM PANCHAYAT- Chatarpur

BLOCK- Shahabad

DISTT- Rampur

**NAME OF AGENCY**

M/s PNC-SPML-JV

Moradabad

22, CAMAC STREAT, BLOCK-A, 3<sup>rd</sup> FLOOR, KOLKATA-700016



**GROUND WATER SURVEY CONSULTANCY**

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- CHATARPUR, BLOCK- SHAHABAD, DISTT- RAMPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :


A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 120 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Moradabad.

On the request of M/S PNC-SPML-JV, Moradabad. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 14.May.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 16	11	Dry sand	
3.	16 - 26	10	Fine sand	
4.	26 - 31	5	Clay kankar	
5.	31 - 38	7	Fine to Medium sand	Medium
6.	38 - 45	7	Clay kankar	
7.	45 - 50	5	Fine sand	Medium
8.	50 - 55	5	Clay kankar	
9.	55 - 70*	15	Medium sand	Medium
10.	70 - 75	5	Clay kankar	
11.	75 - 93*	18	Fine to Medium sand	Medium
12.	93 - 100	7	Clay kankar	
13.	100 - 106*	6	Fine to Medium sand	Medium
14.	106 - 112	6	Clay kankar	
15.	112 - 120*	8	Fine to Medium sand	Medium


Ground Water Survey Consultancy



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

Rho a  
 N 16(SN)  
 N 64 (LN)  
 LAT  
 Location: Logging Co. Chandra  
 Eco-Station Dm  
 Station: UP/LOGS/516  
 Log No.: 14.10/2013  
 Date: 20.11.2013  
 Time: 11.10/2013  
 Operator: United Geom. S.S.  
 Well Depth:

Log No.: GIS/S/01/21-22  
 SP  
 Logger Model: DMPL-2  
 Logger Owned by: GROUND WATER SURVEY CONSULTANCY AGRA, UP India

