


**ACTUAL T.W. ASSEMBLY CHART OF RIKHPUR W/S SCHEME SULTANPUR
UNDER JAL JEEVAN MISSION : (BLOCK - LAMBHUA)**



Bore size - 600 mm X 450 mm
 T.W. Assy - 300 mm X 150 mm
 Discharge - 800 LPM
 LOGGING DATE: 05/05/2023
 LOWERING DATE: 06/05/2023

Logging Report :

S.NO	Depth Range From M.B.G.L	Depth Range M.B.G.L	Thickness Mtr	Inferred Lithology	Quality of G.W.
01	15	19	04	Fine to medium sand	Good
02	25	39	14		
03	79	86	07		

PIPE DETAIL

HOUSING PLAIN PIPE@300MM	=48.00 M
SLOTTED PIPE@300MM	=12.00 M
PLAIN PIPE@150MM	=25.80 M
SLOTTED PIPE@150MM	= 6.00 M

PEA GRAVEL

Total = 91.50 + 0.50 (AGL)
 =92.00 M



VTL-GAJA ENGG JV

JUNIOR ENGINEER

ASSISTANT ENGINEER

EXECUTIVE ENGINEER

M/s Mahalaxmi Tubewell

Rajnendra Nagar Pukhrayan Kanpur 9935299290

Geophysical Well Logging Report

Ref No -05/42

Date-05/05/2023

Site Location : - Rikhpur Lambhuwa Sultanpur

District : - Sultanpur

Logged Depth : - ~~265 M BGL~~

Date of Logging : - 05/05/2023

Types of Log : - S.P&N16, N-64 LAT

Logger used : - IGIS

Rm- 13.9 Qm Rw- 14.8 Qm

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	15	19	04	Fine to Medium sand	Good
02	25	39	14		
03	79	86	07		

Note- All zones are intermixed with fine bands of kankar. Quality of the formation water is deteriorating from 95 Mbgl to tilld logged depth.


Logging performed as per SWIS guidelines. Groundwater quality interpreted by firm as per their logger calibration.

(Signature)

M/s Mahalaxmi Tube Well

*GISh
06/05/23*

Proposed Assembly 4 shaft chart of Rikhpur block
 Ambawa Dist. Sultanpur.



Discharge - 800 LPM
 Assembly - 300x150
 Logging Report
 15-19 → 4
 25-39 - 14 m
 79-86 - 07 m } Final.